



Certificate of Compliance

Certificate: 1607150 (LR 21451-73)

Master Contract: 166730

Project: 1670870

Date Issued: 2005/06/24

Issued to: Idec Izumi Corporation
7-31 Nishimiyahara 1-chome
Yodogawa-Ku, Osaka 532-8550
Japan

The products listed below are eligible to bear the CSA Mark shown



Issued by: John Lam, CET 

Authorized by: Nick Alfano, Operations
Manager



PRODUCTS

CLASS 3211 07 - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Cam switches, Models ACSNO, ACSNK, UCSQO and UCSQM, each rated 5A, 120V ac Res; 3A, 240V ac, Res; 2A, 480V ac Res; 1A, 600V ac Res; 8A, 24V dc; 3A, 110V dc; 1A, 220V dc; 0.4A, 440V dc; A600 and P600 pilot duty.

Notes:

1. The catalogue designations of the above switches have suffix letters and digits as described under 'nomenclature'.
2. The above open type devices are Certified as components for use only in other Certified equipment, where the suitability of the combination is determined by the CSA International.



CSA INTERNATIONAL

Certificate: 1607150 (LR 21451-73)

Master Contract: 166730

Project: 1670870

Date Issued: 2005/06/24

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 14-91 - Industrial Control Equipment